

17.16.030: CULINARY WATER:

- A. The subdivider shall be responsible for installing all off site and on site water mains. All on site mains shall be installed in such a way that each lot may be served therefrom. All mains shall extend to the boundaries of the subdivision.
- B. All water mains shall be sufficient in size to provide a volume of flow and level of pressure adequate for culinary use (in accordance with state and city standards) and fire protection purposes, provided, that no water main shall be less than eight inches (8") in diameter.
- C. Water service laterals shall be installed from the main line to the outer edge of any road proposed to be dedicated to the city. The service laterals shall be not less than one inch (1") diameter and shall consist of: 1) the corporation stop adjacent to the main line, 2) the lateral pipe running from the main to the edge of the adjacent lot, and 3) the stop and waste valve, meter box and meter setter located adjacent to the public right of way immediately adjacent to the property line.
- D. All mains and laterals shall be constructed prior to the installation of road base and hard surfacing of the road and the construction of curb, gutter and sidewalk improvements.
- E. Each lot shall be served by a water lateral connected to an in service city water trunk line. (Ord. 2002-04, 3-20-2002)